

시험 성적서 (TEST REPORT)



성적서 번호 : 15-047364-01
Report No.

페이지 (1) / (총 2)
Page of Pages



1. 의뢰자 (Client)

기관명 (Name) : 건흥전기(주)

주소 (Address) : 서울시 동대문구 한천로 183 (장안동)

의뢰일자 (Date of Receipt) : 2015. 08. 12.

2. 시험성적서의 용도 (Use of Report) : 품질관리용

3. 시험대상품목/물질/시료명 (Test Sample)

제품명 (Description) : PUSH BUTTON

제작회사 (Manufacturer) : 건흥전기(주)

모델명 (Model Name) : NF25W-PM

제조번호 (Serial Number) : -

기타 (Remark) : -

4. 시험기간 (Date of Test) : 2015년 08월 17일 ~ 2015년 08월 18일

5. 시험규격/방법 (Test Standard/Method) : IEC 60529 : 2001 (KS C IEC 60529:2006)

6. 시험환경 (Testing Environment)

온도 (Temperature) : (26.1 ± 2.0) °C, 습도 (Humidity) : (67 ± 2) % R.H.

7. 시험결과 (Test Results) : 별첨결과 참조 (Refer to the attached results)

비고 (Note) : 1. 이 성적서는 의뢰자가 제출한 시료에 대한 시험결과이며,
(The test results contained apply only to the test sample(s) supplied by the client)
2. 우리 원의 사전 동의 없이 본 성적서의 전부 혹은 일부를 복사를 할 수 없습니다.
(This test report shall not be reproduced in full or in part without approval of the KTL in advance.)

확 인 Affirmation	작성자 (Tested by)	기술책임자 (Technical Manager)
	성명 (Name) : 김창호 (Signature)	성명 (Name) : 김지훈 (Signature)

위 성적서는 국제시험기관인정협력체 상호인정협정에 서명한 한국인정기구로부터 공인받은 분야에 대한 시험결과입니다.
(The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.)

2015. 08. 19.

한국인정기구 인정
Accredited by KOLAS, Republic of KOREA

한국산업기술시험원장



서울특별시 구로구 디지털로26길 87 (87, Digital-ro 26-gil, Guro-gu, Seoul, KOREA) Tel.02-860-1531 Fax. 02-860-1549

FP202-01-03

※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

시험 결과

외함의 밀폐 보호 등급 구분(IP Code)

1. 시험결과

코드문자	IP	시험조건 및 시험	결과
제1특정수 외부 고체 물체의 침투에 대한 보호	5	1. 시험조건 1.1 시험용 활석분진의 표준체 와이어 공칭지름: 50 μm 1.2 시험용 활석분진의 표준체 와이어 간격 : 75 μm 1.3 단위부피당 활석분진의 양 : 2 kg/m^3 2. 시험 2.1 시료의 내용적 : 시험박스 약 1200 cm^3 2.2 시료의 내부압력 : -2.0 kPa(-200 mmH ₂ O) 2.3 시료의 공기 흡입량 : 0.02 LPM 2.4 시료의 내용적 대비 시간당 공기 흡입율 : 1 배 2.5 시험시간 : 8 시간	적합
제2특정수 위험한 영향을 주는 물의 침투에 대한 보호	4	1. 시험조건 1.1 분사 노즐 : 직경 0.5 mm의 구멍 121개를가진 노즐 1.2 노즐에서의 유속 : 10 \times (1 \pm 5%) LPM 1.3 분사 압력 : 50 kPa 1.4 노즐과 시료 표면 사이의 거리 : 30 cm ~ 50 cm 2. 시험 2.1 시험 시간 : 5 분	적합

2. 참고사항

- (1) 등급 : IP54
- (2) Size : 34.5 mm \times 37 mm \times 62.2 mm
- (3) 정격 : AC 250 V, 6 A
- (4) 동일형식 : NF25GW-PM, NF25W-PEM, NF25GW-PEM, NF25W-PA, NF25GW-PA, NF25W-BM, NF25GW-BM, NF25W-BA, NF25GW-BA, NF25W-BEM, NF25GW-BEM, NF25W-PER, NF25GW-PER (34.5 mm \times 37 mm \times 62.2 mm)
- (5) 상기 시험성적은 푸쉬버튼을 임의의 시험박스(내용적 1200 cm^3)에 장착하여 시험한 결과임.

TEST REPORT



한국산업기술시험원
Korea Testing Laboratory

Report No. : 15-047364-01

Page of Pages : (1) / (2)



1. Client

Name : KUN HUNG ELECTRIC CO., LTD.

Address : 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

Date of Receipt : 2015. 08. 12

2. Use of Report : For Quality Control

3. Test Sample

Description : PUSH BUTTON

Manufacturer : KUN HUNG ELECTRIC CO., LTD.

Model Name : NF25W-PM

Serial Number : -

Remark : -

4. Date of Test : 2015. 08. 17. ~ 2015. 08. 18.

5. Test Standard/Method : IEC 60529: 2001 (KS C IEC 60529:2006)

6. Testing Environment : Temperature : (26.1 ± 2.0) °C , Humidity : (67 ± 2) % R.H.

7. Test Results : Refer to the attached results

- Note : 1. The test results contained apply only to the test sample(s) supplied by the client
2. This test report shall not be reproduced in full or in part without approval of the KTL in advance.

Affirmation	Tested by		Technical Manager	
	Name : Kim Chang-ho	(Signature)	Name : KIM JI-HOON	(Signature)

The above test report is the accredited test result by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

2015. 08. 19

Korea Testing Laboratory

Accredited by KOLAS, Republic of KOREA



87, Digital-ro 26-gil, Guro-gu, Seoul, KOREA Tel.+82-2-860-1531 Fax. +82-2-860-1549

FP202-03-03



※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

TEST RESULTS

for Degree of protection provided by enclosures(IP Code)

1. Test Results

Code letters	IP	Test method and Record	Results
1st Characteristic numerals Against ingress of solid foreign objects	5	1. CONDITIONS 1.1 Talcum powder(mesh) : Wire diameter=50 μ m, width between wires=75 μ m 1.2 Amount of talcum powder of the test chamber : 2kg/m ³ 2. TEST 2.1 Volume of the enclosures : test box about 1200 cm ³ 2.2 Reduction air pressure : -2.0 kPa (-200 mmH ₂ O) 2.3 Flow rate : 0.02 LPM 2.4 Extraction rate per hour : 1 volumes/h 2.5 Test duration : 8 hours	Pass
2nd Characteristic numerals Against ingress of water with harmful effects	4	1. CONDITIONS 1.1 Spray nozzle : \varnothing 0.5mm, 121 holes(Refer IEC 60529 Fig. 5) 1.2 Water flow rate : 10 \times (1 \pm 5 %) LPM 1.3 Delivery rate(Pressure) : 50 kPa 1.4 Distance from nozzle to enclosure surface : 300 mm ~ 500 mm 2. TEST 2.1 The duration of the test is : 5 minutes	Pass

2. Reference Data

- (1) IP Code : IP54
- (2) Size : 34.5 mm \times 37 mm \times 62.2 mm
- (3) Rating : AC 250 V, 6 A
- (4) Identical Model : NF25GW-PM, NF25W-PEM, NF25GW-PEM, NF25W-PA, NF25GW-PA, NF25W-BM, NF25GW-BM, NF25W-BA, NF25GW-BA, NF25W-BEM, NF25GW-BEM, NF25W-PER, NF25GW-PER (34.5 mm \times 37 mm \times 62.2 mm)
- (5) Test is only button part.